



#### CABLE GLANDS:

—Connections: 2xM50x1.5(ø24 min.—ø35 max.cable) .  
1xM20x1.5(ø9 min.—ø14 max.cable) .



TAG	QTY	ASSOCIATED EQUIPMENT	FLOW RATE (m3/h)	ELECT. POWER (kW)	VOLTAGE	CLASS.	APROX. WEIGHT (Kg)
PMP—CHW00001	1		97	35	3x440/60	W	449
PMP—CHW00002	1		97	35	3x440/60	W	449
PMP—CHW00003	1		97	35	3x440/60	W	449

F	UPDATED	06/06/19	JCR	MRH	MRH
E	UPDATED	18/03/19	JCR	MRH	MRH
D	UPDATED	12/02/19	JCR	MRH	MRH
C	UPDATED	05/03/18	JPA	MRH	MRH
B	UPDATED	17/10/17	JCR	MRH	MRH
A	FOR INFO./COMMENTS	07/08/17	JCR	MRH	MRH
REV.	DESCRIPTION	DATE	DRAWN	VERIFIED	APPROVED

PROJECT:	AVANTE 2200				
DESCRIPTION:	CHILLED WATER PUMPS	DRAWING NUMBER: P—M05462—013			
SCALE:	NTS	FORMAT:	A3	SHEET:	01/02

