

· SYSTEM: HVAC





PROJECT: AVANTE 2200

SHIPYARD:

XNavantia

SYSTEM: HVAC

SEA WATER COOLING COILS

REF.: D-MO5462-015

REV	DESCRIPTION	DATE	ISSUED BY	CHECKED BY	APPROVED BY
0	For information / and comments	31/03/2017	ASC	AMF	MRH
А	For information / and comments. Updated	19/05/2017	ASC	AMF	MRH
В	Updated	07/08/2017	JCR	MRH	MRH
С	Updated	24/08/2018	JCR	MRH	MRH
D	Full update according received comments	30/07/2019	JCR	MRH	MRH
E	Updated	02/08/2019	ATR	JMC	MRH
F	Updated	27/11/2019	AMG	AMF	MRH



· SYSTEM: HVAC









Before carrying out any operation on the machines of the HVAC System, please read this installation and operation manual carefully.

Installation and maintenance must be carried out only by qualified personnel that is familiar with the provisions of law and local regulations and has been trained properly or has experience with this type of equipment.

WARNING

2



Avoid installing the HVAC System equipment in a place that could be dangerous during maintenance operations, such as (but not only) platforms without railings or areas not complying with the clearance requirements.



· SYSTEM: HVAC





INDEX

1 Functional F	Description	4
1.1 ItemLi	4	
2. Installation		5
2.1 Installat	ion location	5
2.2 Connec	ting the sea water	5
3. Troubleshoo	eting	6
ANNEXES		
Annex A	Technical data sheets	
Annex B	Drawings	



· SYSTEM: HVAC





1. Functional Description

The engine rooms, diesel generator rooms and auxiliary machinery room ventilation systems will have sea water/air heat that will allow maintaining maximum machinery rooms temperature below 45°C (sea water temperatures below 35°C).

The air inside these machinery rooms will be recalculated through the seawater/air heat exchangers to be cooled.

1.1 ItemList

Table 1. Item List

TAG DESCRIPTION	TAG	MAKER	COOLING ACITY (KW)	Se <u>a</u> water flow (m3/h)	CLASSIFICATION
Sea water coil	HEX-VES01001	3S	11,98	3,43	W
Sea water coil	HEX-VES01002	3S	85,00	26,11	W
Sea water coil	HEX-VES01003	3S	85,00	26,11	W
Sea water coil	HEX-VES01006	3S	100,00	30,71	W
Sea water coil	HEX-VES01007	3S	100,00	30,71	W
Sea water coil	HEX-VES02004	3S	85,00	26,11	W
Sea water coil	HEX-VES02005	3S	85,00	26,11	W
Sea water coil	HEX-VES02008	3S	100,00	30,71	W
Sea water coil	HEX-VES02009	3S	100,00	30,71	W

Table 2. Item List

Ì

TAG DESCRIPTION	TAG	WEIGHT (KG)	DIMENSIONS (LxWxH) (mm)
Sea water coil	HEX-VES01001	80	1190x355x810
Sea water coil	HEX-VES01002	590	2630x460x1810
Sea water coil	HEX-VES01003	590	2630x460x1810
Sea water coil	HEX-VES01006	730	1680x460x3350
Sea water coil	HEX-VES01007	730	1680x460x3350
Sea water coil	HEX-VES02004	590	2630x460x1810
Sea water coil	HEX-VES02005	590	2630x460x1810
Sea water coil	HEX-VES02008	730	1680x460x3350
Sea water coil	HEX-VES02009	730	1680x460x3350



· SYSTEM: HVAC





2. Installation

NOTE

You must ensure that no mechanical deformation or twisting occurs during installation of all models in all installation locations.

2.1 Installation location

This paragraph gives the conditions under which the units may be stored:

The type, condition and ambient temperature of the installation location must be suitable for the unit in question.

Observe the following points:

- Only install the unit in enclosed spaces.
- Mounting systems must be capable of bearing the weight of the unit.
- Ensure that suitable fixings (screws, plugs, etc.) are used which correspond.

2.2 Connecting the sea water

Before the on-site piping and the unit sea water connection is set up, the sea water system should be shut off and secured against being opened unintentionally.

Connection to the pipe system is made by the pipe contractor. Cooling coils must always be connected in counter flow (supply and discharge pipes are marked) and so that the own weight of the pipe system does not load the pipe connections of the coils. The connections of the coils are designed as flanged pipes and so they must be secured to avoid distortion and damage to the internal pipe system of the coil.

Cooling coils are equipped with a drip pan with drain through the base frame extended through the access side for condensate. Clean the cooling coils by flushing with water, also clean the drip pan as drain must be kept clean to avoid formation of algae.

When all connections have been completed, all screw connections should be tightened and checked that they are free of mechanical stress.





- Risk of damage to the unit.
- During fitting, the connection nut on the cooling coil should be countered using a suitable tool.

CAUTION

• At the beginning of the fitting procedure, remove the covers of the water inlet and outlet pipes.

5

- Fit the connections, ensuring they are free of mechanical stress.
- Seal the connections.
- Screw on the connections.



· SYSTEM: HVAC





3. Troubleshooting

Deviations from normal operating states of the sea water cooling coil units are evidence of malfunctions and must be investigated by maintenance personnel.

The following table should serve as a starting point for maintenance personnel regarding possible causes of trouble and their correction:

Table 3 - Troubleshooting

Troubleshooting Code	Fault	Possible cause of fault	Remedy	Associated Maintenance Task
	Unit does not	Dirty filter	Clean/replace the filter (mechanic)	PM-1
TB-1	insufficiently (chilled water)	Cooling medium is not cold	Check the chilled water system (mechanic)	-
		Water flow rate too low	Check the chilled water system (mechanic)	-
TB-2	Water	Drip pan drain blocked	Clean condensate drain and check for sufficient gradient, clean and fill the the water trap if necessary (mechanic)	-
	leakage in unit area	Cooling coil or hydraulic connections leaking	Check the cooling coil, bleeding and valve connections for leaks If necessary, retighten connections, clean screw insert or reseal the connections (mechanic)	

If the malfunction cannot be fixed by the maintenance personnel, please consult FRIZONIA



· SYSTEM: HVAC





Annex A

Technical Information



HVAC · SYSTEM:





ENGINE ROOMS

TAGS: HEX-VES01006, HEX-VES01007, HEX-VES02008, HEX-VES02009

FIN	SIDE			Fluid: AIR		
Quantity Specific		m3/h kg/m3	41000 1,057	Dry air	kg/h	43337
Inlet	Dry bulb temp. Wet bulb temp. Absolute humid.	°C °C g/kg	45,0 34,2 30,20	Relative humid. Enthalpy	% kJ/kg	49 123,30
Outlet	Dry bulb temp. Wet bulb temp. Absolute humid.	°C °C g/kg	37,2 32,8 30,2	Relative humid. Enthalpy	% kJ/kg	74 114,97
Face vel	•	m/sec kW	2,47 100,00	Pressure drop Sensible heat ratio	Pa	112 1,00
TUBE	SIDE			Fluid: SEA WATER		
Quantity I/h 30 Inlet temp. °C		30714 35,0 1,44	Outlet temp. Pressure drop	°C kPa	37,8 50,9	
COILT	YPE P40-16 AF	R 6R - 78T - 147	5A - 2,5Pa	CuNi-10/Cu NC = 33		
COIL	COIL CARACTERISTIC				I3S Re18r (Tr0)	-T0 -5,89-A0
Surface m2 682,9 - Fluid content dm3 156 Finned length mm 1475 - Finned heigth mm 3120 Fouling factor Cm2/W 0,00020 - Finned heigth mm 3120				dm3 156,4		

Heat exchanger exempt from testing in conformity to PED 2014/68/EU directive - Art. 4.3 Design pressure and temperature (inside tubes) 10,0 bar / 100,0°C Attention: Dimension in height > 2480- transport difficulty

NOT tested according	to Eurovent	certification
140 I tested according	to Eurovent	ceranication

				Teo i teolea according	o Eurovent och	moderon
MATERIALS						
Exchange tube	CuproNichel 10	- Diameter	mm 16,50	- Thickness	mm	0,70
Fins	Copper	 Thickness 	mm 0,10			
Headers	CupperNichel 10	- Frame	Stainless steel A316L	 Connections 	Flange	d
Flanges	Fe EN 1092-1 Type 11	- PN16 (ex UNI 2282	- ex DIN 2633)			



· SYSTEM: HVAC





Annex B

Drawings

